

**Self Monitoring Sampling Frequencies  
For  
Categorical Industrial Users**

The following schedule shall be used to determine self monitoring sampling frequency for permitted Categorical Industrial Users:

<u>Regulated Wastewater Discharge Volume in Gallons per working day</u>	<u>Sampling Frequency</u>
0 – 10,000	1 sample per month
10,001 – 50,000	2 samples per month
50,001 – 100,000	1 sample per week
100,001 – 250,000	2 samples per week
Over – 250,000	3 samples per week